

3/28/26, 7:31 PM

A.P. State Disaster Response and Fire Services Department

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
Regional Fire Officer
Zone-4, Kurnool
Andhra Pradesh.

To:
District Education Officer, Sri Sathya Sai
District, Puttaparthi.,

File No: 30974/SSS/RFO/2026, Date: 28/03/2026
Occupancy No: RC Number: 251/RFO/SR/2014

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Yasoda English Medium High School, represented by Malagundla Prithvi Raj, D.No.26/789, PEDDAIAH GARDENS, PUTTAPARTHI ROAD, DHARMAVARAM, SATYA SAI DISTRICT, ANDHRA PRADESH 515671** District-515671 - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 251/RFO/SR/2014, Dt.28/08/2014
 4. Renewal NOC For Occupancy 251/RFO/SR/2014, Dt.11/04/2025
 5. Online Application for Renewal NOC of Malagundla Prithvi Raj, D.No.26/789, PEDDAIAH GARDENS, PUTTAPARTHI ROAD, DHARMAVARAM, SATYA SAI DISTRICT, ANDHRA PRADESH 515671 District-515671 - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 26-03-2026.

-- X --

The Management of Yasoda English Medium High School, represented by Malagundla Prithvi Raj, D.No.26/789, PEDDAIAH GARDENS, PUTTAPARTHI ROAD, DHARMAVARAM, SATYA SAI DISTRICT, ANDHRA PRADESH 515671 District-515671 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.125000/- vide challan No. 91416442672025, Dated 26/03/2026 at CFMS, Online.

Block - I, Block - II

1. This certificate is being issued as per G.O.Ms.No:218, Home(Prisons & Fire), Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Malagundla Prithvi Raj D.No.26/789, PEDDAIAH GARDENS, PUTTAPARTHI ROAD, DHARMAVARAM, SATYA SAI DISTRICT, ANDHRA PRADESH 515671** District-515671, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
	Addition / alteration, if any in the	Mock drills should be conducted once	All security personnel shall be trained

M. Dhanalakshmi
Principal
Yasoda English Medium High School
Puttaparthi Road, Dharmavaram.
Sri Sathya Sai Dist - 515 671.

M. Pruthvi
Secretary
Yasoda English Medium High School
Puttaparthi Road, Dharmavaram.
Sri Sathya Sai Dist - 515 671.

3/28/26, 7:31 PM

A.P. State Disaster Response and Fire Services Department

4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.
---	---	--	--

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 11/04/2026 to 10/04/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91416442672025	2026-03-26	125000

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

- This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee. It doesn't confer proprietary or ownership rights. If any deviations are noticed post-issuance, this NOC is liable for cancellation at any time.
- The management must maintain fire safety measures and installations in good working condition. Responsibility for firefighting equipment maintenance lies with the management, as verified by the committee during inspection.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సुरక్షిత పాఠశాలలు, సురక్షిత మైన్ ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై సమూహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
Regional Fire Officer
Zone-4, Kurnool
Andhra Pradesh.

In case of emergency, please call 101 or 08559 – 220626 or 9963740213

Copy to Malagundla Prithvi Raj, Yasoda English Medium High School, D.No.26/789, Peddaiah Gardens Puttaparthi Road, Dharmavaram, Sri Sathya Sai District-515671.

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

M. Dhanalakshmi
Principal
Yasoda English Medium High School
Puttaparthi Road, Dharmavaram.
Sri Sathya Sai Dist - 515 671.

[Signature]
Secretary
Yasoda English Medium High School
Puttaparthi Road, Dharmavaram.
Sri Sathya Sai Dist - 515 671. -